

WATER VALVE/FAUCET REPLACEMENT RE-TESTING SCHEDULE

Building	Location	First Draw	Flush	Valve/ Faucet Replacement Date	Re-Test Date	First Draw	Flush	2nd Re- test Date	First Draw	Flush	3rd Re- test Date	First Draw	Flush	4th Re- test Date	First Draw	Flush	5th Re- test Date	First Draw	Flush	Comments
TJ	Room 136 - Sink	11.20	0.00	1/20/18	1/30/18	21.60	0.00	2/22/18	14.50	0.00	3/27/18	2.16	0.00							
	Room 138 - Sink	5.78	18.20	1/20/18	1/30/18	36.30	0.00	2/22/18	14.20	0.00	3/27/18	6.18	0.00	5/31/18	5.93	0.00	11/13/1	3.28	0.00	
	Classroom 111 - Sink #1	7.79	0.00	1/20/18	1/30/18	9.27	0.00	2/22/18	17.70	0.00	3/27/18	2.42	0.00							
	Classroom 111 - Sink #2	5.82	0.00	1/20/18	1/30/18	0.00	0.00		-	-										
	Wet Area 424 - Sink #2	6.31	0.00	1/20/18	1/30/18	71.80	0.00	2/22/18	36.50	0.00	3/27/18	2.41	0.00							
	Wet Area 424 - Sink #4	6.95	0.00	1/20/18	1/30/18	2.14	0.00		-	-										
	Wet Area 426 - Sink #2	7.35	0.00	1/20/18	1/30/18	68.80	0.00	2/22/18	25.80	0.00	3/27/18	0.00	0.00							
	Wet Area 426 - Sink #3	5.34	0.00	1/20/18	1/30/18	21.50	0.00	2/22/18	38.70	0.00	3/27/18	0.00	0.00							
	Wet Area 427 - Sink #3	7.74	0.00	1/20/18	1/30/18	10.70	0.00	2/22/18	19.60	0.00	3/27/18	4.07	0.00							
	Wet Area 429 - Sink #3	6.25	0.00	1/20/18	1/30/18	9.25	0.00	2/22/18	8.48	0.00	3/27/18	0.00	0.00							
FCW	none																			
CLA	2nd Floor East Corridor South - Drinking Fountain	8.38	0.00	2/15/18	2/22/18	0.00	0.00													
	Receiving Area Men's Restroom - Sink	6.02	0.00	3/15/18	2/22/18	31.00	0.00	11/14/1	0.00	0.00	5/8/19	29.20	2.35							
	Receiving Area Women's Restroom - Sink	39.60	0.00	3/15/18	2/22/18	13.00	0.00	11/14/1	21.40	0.00										
	2nd Floor West Corridor Staff Restroom - Sink	4.98	8.66	2/11/18	2/22/18	0.00	0.00													
Classroom 105 Restroom - Sink	4.88	5.11	2/11/18	2/23/18	26.80	2.62	11/14/1	2.26	0.00											
WB	LRC - Sink	7.37	2.94	2/1/18	2/13/18	23.00	0.00	11/14/1 8	8.46	0.00										
CR	1st Floor East Staff Restroom - Sink	6.35	0.00	2/1/18	2/13/18	104.00	0.00	11/14/1	0.00	0.00										
	Classroom 147/150 Restroom - Sink	7.67	0.00	2/1/18	2/13/18	100.00	0.00	11/14/1	0.00	0.00										
CS	LRC Office - Sink	5.38	0.00	1/26/18	2/22/18	28.10	0.00	11/14/1	2.33	0.00										
	Office Restroom - Sink	5.93	0.00	1/26/18	2/22/18	0.00	0.00													
	Science Room B114 - Sink #1 Eye Wash Station	-	5.59	3/15/18																
	Science Room C101 - Sink #3	27.10	3.52	3/15/18																
PG	Kitchen - Sink #2	5.32	0.00	1/5/18	1/23/18	0.00	0.00													
KH	Kitchen - Sink	5.04	0.00	1/5/18	1/30/18	19.00	0.00	2/1/18	41.90	0.00	8/2/18	2.80	0.00							stops
	Room 115 - Sink	5.81	0.00	1/5/18	1/30/18	19.10	0.00	2/1/18	2.41	0.00										stops
	1st Floor North - Drinking Fountain	0.00	6.28	1/31/18	2/1/18	3.20	0.00													
Tremelling	Kitchen - Sink	8.24	0.00	1/27/18	2/1/18	0.00	0.00													
	Bathroom - Sink	6.86	0.00	1/27/18	2/1/18	73.50	0.00													
WC	Classroom 110 - Sink	5.48	0.00	2/25/18	2/28/18	5.33	0.00	11/14/1	2.64	0.00										
	Room C119B - Sink	11.00	0.00	2/25/18	2/28/18	16.40	0.00	11/14/1	2.13	0.00										
	Girls Locker Room Office Restroom - Sink	6.84	0.00	2/8/18	2/28/18	16.70	0.00	11/14/1	0.00	0.00										
	Classroom G101 Restroom - Sink	5.14	0.00	2/8/18	2/28/18	22.10	0.00	11/14/1	0.00	0.00										
	Classroom G102 - Sink	10.00	0.00	3/15/18																
	Classroom G104 - Sink #2	6.79	0.00	3/15/18																
	Classroom G104 - Sink #3	6.90	0.00	3/15/18																

WATER VALVE/FAUCET REPLACEMENT RE-TESTING SCHEDULE

Building	Location	First Draw	Flush	Valve/ Faucet Replacement Date	Re-Test Date	First Draw	Flush	2nd Re- test Date	First Draw	Flush	3rd Re- test Date	First Draw	Flush	4th Re- test Date	First Draw	Flush	5th Re- test Date	First Draw	Flush	Comments	
	Room 104A - Sink	8.52	0.00	3/15/18																	
	Classroom G102 - Sink #2	8.48	0.00	3/15/18																	
	Classroom G106 - Sink #3	7.79	0.00	3/15/18																	
	Room G113B - Sink	14.20	4.39	2/8/18	2/28/18	0.00	26.40	11/14/1	2.39	0.00											
	Classroom G203 - Sink	5.87	0.00	3/15/18	2/28/18	0.00	0.00														
	Classroom G204 - Sink #1	11.00	0.00	3/15/18																	
	Classroom G204 - Sink #4	26.80	5.01	3/15/18																	
	Prep Room G204A - Sink	6.95	0.00	3/15/18																	
	Classroom G206 - Sink #1	7.21	0.00	3/15/18																	
	Classroom G106 - Sink #1	3.47	5.87	3/15/18																	
	Classroom G201A - Sink	0.00	5.89	2/25/18	2/28/18	6.18	0.00	11/14/1	4.44	0.00											
	Classroom G209 - Sink	4.89	13.80	2/25/18	2/28/18	5.66	0.00	11/14/1	4.66	0.00											
SRP	Room 31 - Sink (LRC Office)	13.00	0.00	3/1/18	2/28/18	29.50	0.00	11/13/1	2.17	0.00											
	Classroom 11 - Sink	128.00	0.00	2/24/18	2/28/18	0.00	0.00														
	Classroom 12 - Sink	64.60	2.31	2/24/18	2/28/18	0.00	0.00														
	Classroom 37 - Sink	7.75	0.00	2/24/18	2/28/18	9.13	0.00	11/13/1	0.00	0.00											
	Classroom 36 - Sink	48.80	0.00	2/24/18	2/28/18	32.50	0.00	11/13/1	2.31	0.00											
	Classroom 44 - Sink	8.11	0.00	2/24/18	2/28/18	28.10	0.00	11/13/1	2.08	0.00											
GMS	Classroom 146 - Sink #1	16.10	2.37	2/13/18	2/23/18	52.50	0.00	11/13/1	6.14	0.00	5/8/19	0.00	0.00								
	Room 120D - Sink	21.80	6.55	2/13/18	2/23/18	72.40	0.00	11/13/1	0.00	0.00											
LL	Room 48A - Sink	11.50	4.18	2/17/18	2/23/18	20.60	0.00	8/2/18	5.22	0.00	4/10/19	3.15	0.00	5/8/19	2.44	0.00	10/29/1	3.68	0.00		
	Room 64A - Sink	8.27	0.00	2/17/18	2/23/18	58.20	0.00	8/2/18	6.25	2.88	4/10/19	2.47	0.00	5/8/19	3.00	0.00	10/29/1	2.18	0.00		
	LRC Office - Sink	7.23	2.86	2/17/18	2/23/18	36.20	0.00	8/2/18	6.24	0.00	4/10/19	2.95	0.00	5/8/19	3.05	0.00	10/29/1	5.96	0.00		
	Room 100 Restroom - Sink	5.50	2.18	2/17/18	2/23/18	6.48	0.00	8/2/18	3.14	0.00											
	Classroom 205 - Sink	2.18	5.04	2/17/18	2/23/18	60.20	0.00	8/2/18	7.69	0.00	4/10/19	0.00	0.00	5/8/19	2.86	0.00	10/29/1	4.98	0.00		
	Classroom 109 - Sink	5.29	0.00	2/17/18	2/23/18	33.20	0.00	8/2/18	7.03	0.00	4/10/19	2.38	0.00	5/8/19	0.00	0.00	10/29/1	2.36	0.00		
LS	none																				
HR	Classroom 112 - Sink	6.13	0.00	2/18/18	2/23/18	47.60	0.00	11/13/1	2.06	0.00											
	Creative Learning 117 - Sink	21.10	0.00	2/18/18	2/23/18	9.87	0.00	11/13/1	2.68	0.00											
	TPI 121 - Sink	35.10	4.35	2/18/18	2/23/18	17.60	0.00	11/13/1	3.17	0.00											
	LD Res 123 - Sink	5.05	0.00	2/18/18	2/23/18	17.30	0.00	11/13/1	0.00	0.00											
	LD Res 125 - Sink	5.32	0.00	2/18/18	2/23/18	7.65	0.00	11/13/1	0.00	0.00											
	Classroom 215 - Sink	13.70	5.30	2/18/18	2/23/18	23.00	0.00	11/13/1	2.34	0.00											
JA	Classroom 117 - Sink	8.50	0.00	2/3/18	2/13/18	28.60	0.00	5/3/18	5.72	0.00	8/2/18	5.82	0.00	4/10/19	2.61	0.00					
	Classroom 119 - Sink	10.50	0.00	2/3/18	2/13/18	54.10	3.89	5/3/18	5.30	0.00	8/2/18	2.79	0.00								
	Classroom 120 - Sink	13.60	0.00	2/3/18	2/13/18	37.90	0.00	5/3/18	3.55	0.00	-	-	-								
	Classroom 125 - Sink	6.71	0.00	2/3/18	2/13/18	19.00	0.00	5/3/18	5.98	0.00	8/2/18	31.60	0.00	4/10/19	14.50	0.00	5/8/19	2.12	0.00		
	Classroom 127 - Sink	6.96	0.00	2/3/18	2/13/18	26.60	0.00	5/3/18	6.75	0.00	8/2/18	6.03	0.00	4/10/19	2.93	0.00					
	Classroom 128 - Sink	11.40	0.00	2/3/18	2/13/18	20.80	0.00	5/3/18	7.58	0.00	8/2/18	0.00	0.00								

WATER VALVE/FAUCET REPLACEMENT RE-TESTING SCHEDULE

Building	Location	First Draw	Flush	Valve/ Faucet Replacement Date	Re-Test Date	First Draw	Flush	2nd Re- test Date	First Draw	Flush	3rd Re- test Date	First Draw	Flush	4th Re- test Date	First Draw	Flush	5th Re- test Date	First Draw	Flush	Comments	
	Classroom 111 - Sink	22.90	0.00	2/3/18	2/13/18	17.20	0.00	5/3/18	3.47	0.00	-	-	-								
MJ	TPI Room 31 - Sink	14.40	0.00	1/20/18	2/1/18	2.70	0.00														
	Room 30B - Sink	5.53	0.00	1/20/18	2/1/18	2.24	0.00														
	Special Ed/Psych Hall - Sink	11.60	0.00	1/31/18	2/1/18	17.60	0.00	11/14/1	6.23	0.00	5/8/19	7.35	0.00	10/22/1	8.65	0.00					
	Room 80 - Sink	10.20	19.80	1/20/18	2/1/18	9.72	0.00	11/14/1	0.00	0.00											
	Room 74 - Sink	8.73	0.00	1/20/18	2/1/18	35.20	0.00	11/14/1	4.97	0.00											
	Nurse's Office Restroom - Sink	5.50	0.00	1/20/18	2/1/18	2.35	0.00														
	Room 19B - Sink	43.90	0.00	1/20/18	2/1/18	14.10	0.00	11/14/1	3.35	0.00											
	Classroom 20 Restroom - Sink	8.76	0.00	1/20/18	2/1/18	39.00	0.00	11/14/1	0.00	0.00											
WRS	Meeting Room 203 - Sink	8.58	0.00	2/14/18	2/23/18	6.03	0.00	11/14/1	2.08	0.00											
	Classroom 303 - Sink #1	6.83	0.00	3/15/18																	
	Classroom 303 - Sink #5	12.70	0.00	3/15/18																	
	Classroom 307 - Sink #3	22.00	0.00	3/15/18																	
	Classroom 217 - Sink #7	5.10	0.00	3/15/18																	
PH	Room 101E - Sink	19.10	0.00	2/11/18	2/13/18	4.46	0.00														
VL	Classroom 101 Restroom - Sink	6.21	0.00	2/10/18	2/13/18	12.80	0.00	5/4/18	0.00	0.00											
	Classroom 103 Restroom - Sink	78.00	2.42	2/10/18	2/13/18	72.00	0.00	5/4/18	6.26	0.00	11/14/1	3.68	0.00								
	Classroom 107 - Sink #1	44.40	2.42	2/10/18	2/13/18	36.30	0.00	5/4/18	7.64	0.00	11/14/1	3.25	0.00								
	Classroom 109 - Sink	7.35	0.00	2/10/18	2/13/18	28.00	0.00	5/4/18	2.49	0.00											
	Classroom 117 - Sink	8.18	0.00	2/10/18	2/13/18	12.50	0.00	5/4/18	2.43	0.00											
	Classroom 118 - Sink	9.42	0.00	2/10/18	2/13/18	294.00	0.00	5/4/18	5.49	0.00	11/14/1	3.68	0.00								
	Room 135 - Sink	8.89	0.00	2/10/18	2/13/18	31.70	0.00	5/4/18	5.25	0.00	11/14/1	3.79	8.94								