

ADDENDUM NO. 2

**ROOFTOP AHU REPLACEMENT AT JOSEPH M. KISZKA
EDUCATIONAL SERVICE CENTER**

Community Consolidated School District 15

STR PARTNERS LLC

350 West Ontario Avenue-Suite 200

July 27, 2015

STR Project #15045

CCSD15 Bid #16-001

Chicago, Illinois 60654

Construction Drawings, Specifications, and Bidding Documents for the above captioned Project, dated July 15, 2015, are revised, amended, and clarified as follows. All provisions of the original Drawings and Specifications shall remain in force, except as specifically modified or changed herein, or by other Addenda.

A. SPECIFICATIONS:

1. Section 15975:

- a. **Add** the following paragraph to 1.03-A: "6. System graphics shall include individual equipment graphics such as RTUs, VAVs, FPBs, EFs, etc., as well as a boiler room layout. Graphics shall also include 1st & 2nd floor building layouts with active zone temperature display. Architect/Engineer will provide CAD floor plans as well as existing HVAC drawings to the contractor for this purpose."

B. DRAWINGS:

1. SHEET ME1.1:

- a. **Replace** entire sheet with new ME1.1 drawing attached.

2. SHEET ME2.0:

- a. **Replace** entire sheet with new ME2.0 drawing attached.

END OF ADDENDUM NO. 2